



- NOTES:**
- 1) VALVES SHALL BE AVK OR SIMILAR APPROVED RESILIENT SEAL TYPE, LEFT HAND CLOSING CLASS 16 WITH NON RISING SPINDLES.
 - 2) VALVE CHAMBERS TO BE CONSTRUCTED IN ACCORDANCE WITH DRAWING W1.
 - 3) FIRE HYDRANTS SHALL BE AINSWORTH OR SIMILAR APPROVED TYPE, 65mm INTERNAL DIAMETER LEFT HAND CLOSING WITH LONDON ROUND THREAD.
 - 4) HYDRANT CHAMBER TO BE CONSTRUCTED IN ACCORDANCE WITH DRAWING W2.
 - 5) ALL BENDS, TEES, REDUCERS ETC. SHALL BE DUCKTILE IRON TO EN 12842.
 - 6) STAINLESS STEEL BOLTS & NUTS TO BE USED ON ALL FITTINGS.
 - 7) HOUSE CONNECTIONS SHALL BE INSTALLED AS INDICATED ON DRAWING W3.
 - 8) BACKFILLING OF TRENCHES IN ACCORDANCE WITH SABS 1200 DB 5.6 AND 5.7 AS WELL AS SABS 1200 LB DRAWING LB-1 AND LB-2.

LEGEND

| | |
|----------------------------------|-------|
| 200mm Ø UPVC CLASS 12 WATER MAIN | ----- |
| 50mm Ø HDPE PIPE | ----- |
| FIRE HYDRANTS | |
| VALVES | |
| BULK WATER METER | |

| | | | | | |
|--------------|-----------|----------|--------------|--------------------|--------|
| CHECKED | L.W.(CAD) | FEB 2009 | NAGESIEN | SCALE AS DRAWN | 1: 500 |
| DRAWN | AVDIS | FEB 2009 | GETERKEN | SKAAL SOOS GETEKEN | |
| DESIGNED | | | ONTWERP | SURVEY DATUM | |
| SURVEYED | | | ORGEMEET | M.S.L. | |
| SURV DISK No | | | SURV DISK Nr | OPMEET DATUM | |
| CAD DISK No | | | CAD DISK Nr | | |

100 MM ON ORIGINAL DRAWING

100 MM OP OORSPRONKLIKE TEKENING

ROBERT LESLIE
CONSULTING ENGINEERS - RAADGEWENDE INGENIEURS

10 PINNENRDE CENTRE
17 ME BOTTMAN STREET
FARM 725/61, KRAAIFONTEIN, NORTH
7300

TEL: (021) 930-7354 FAX: (021) 930-4609 E-MAIL: rls@robertleslie.co.za

| | | | | |
|---|---------------------------------------|------------|------------|----------|
| F | | | | |
| E | | | | |
| D | | | | |
| C | | | | |
| B | AMENDMENTS AS PER MUNICIPAL COMMENTS | FEB 2009 | H.A. MOSER | |
| A | DESIGN AMENDED TO SUIT REVISED LAYOUT | JAN 2009 | H.A. MOSER | |
| | DESCRIPTION | DATE | PR. ENG. | |
| | DESCRIPTION | BESKRYWING | DATUM | PR. ING. |
| | AMENDMENTS | WYSIGINGS | | |

| | |
|---------------|--|
| CLIENT/KLIENT | PRECIOUS PROSPECT TRADING 168 (PTY) LTD |
| | CONSTR. ENGR./RAADG. IN |
| | H.A. MOSER PR. ENG. ECSA REG. NO 730377 |

PRECIOUS PROSPECT TRADING 168 (PTY) LTD

DEVELOPMENT OF FARM 725/61, KRAAIFONTEIN (BUH-REIN ESTATE)

| | |
|-------------|----------|
| DRAWING NO. | 08P03/15 |
| TEK NR. | |
| AMENDMENTS | |
| A | |
| B | |
| WYSIGINGS | |