



- NOTES:**
- 1) VALVES SHALL BE AVK OR SIMILAR APPROVED RUBBER SEAL TYPE LEFT HAND CLOSING CLASS 16 WITH NON ENDING SPINDLES.
 - 2) VALVE CHAMBERS TO BE CONSTRUCTED IN ACCORDANCE WITH DRAWING W1.
 - 3) FIRE HYDRANTS SHALL BE AINWORTH OR SIMILAR APPROVED TYPE 65mm INTERNAL DIAMETER LEFT HAND CLOSING WITH LONDON ROUND THREAD.
 - 4) HYDRANT CHAMBER TO BE CONSTRUCTED IN ACCORDANCE WITH DRAWING W2.
 - 5) ALL BENDS, TEES, REDUCERS ETC. SHALL BE DUCKLE BORN TO EN 1284.
 - 6) STAINLESS STEEL BOLTS & NUTS TO BE USED ON ALL FITTINGS.
 - 7) HOSE CONNECTIONS SHALL BE INSTALLED AS INDICATED ON DRAWING W3.
 - 8) BACKFILLING OF TRENCHES IN ACCORDANCE WITH SANS 12018 1 & 2 AS WELL AS SANS 12018 DRAWING LB-1 AND LB-2.

LEGEND	
200mm ø UPVC CLASS 12 WATER MAIN	---
50mm ø HDPE PIPE	---
FIRE HYDRANTS	⊕
VALVES	⊕
BULK WATER METER	⊕

CHECKED	L.W.(CAD)	FEB 2009	NAGESIEN	SCALE AS DRAWN
DRAWN	AVDS	FEB 2009	GETEKEN	1:1500
DESIGNED	OPGEMEET		SKAAL SOOS GETEKEN	
SURVEYED	SURV DISK N°		M.S.L.	
SURV DISK No	CAD DISK N°		OPMEET DATUM	
CAD DISK No				

100 MM ON ORIGINAL DRAWING

100 MM OP OORSPRONKLIKE TEKENING

ROBERT LESLIE
 CONSULTING ENGINEERS - RAADGEWENDE INGENIEURS

10 PINEHILL CENTRE
 17 ME ROTHSCHILD STREET
 PAROW - NORTH
 7500

TEL: (021) 930-7354 FAX: (021) 930-4660 E-MAIL: rleslie@rleslie.net

F			
E			
D			
C			
B			
A			
DESCRIPTION	BESKRYWING	DATE	PR. ENG.
		DATUM	PR. ING.
AMENDMENTS	WYSIGINGS		

CLIENT/KLIJNT

CONS. ENG./RAADG. IN

H.A. MOSER P. ENG.
 ECSA REG. NO 730377

PRECIOUS PROSPECT TRADING 168 (PTY) LTD

DEVELOPMENT OF FARM 725/61, KRAAIFONTEIN (BUH-REIN ESTATE)

WATER RETICULATION MASTERPLAN

DRAWING NO.	08P03/40
TEK. NR.	
AMENDMENTS	
WYSIGINGS	